

TOWN OF LEXINGTON

Inspection Requirements

**NOTICE TO ALL CONTRACTORS DOING DRAIN / SEWER /WATER PROJECTS
YOU MUST NOTIFY THE ENGINEERING DEPARTMENT 48 HOURS BEFORE
STARTING THE PROJECT AND AGAIN, 2 HOURS BEFORE INSPECTION IS NEEDED.**

**ALL REQUESTS TO ENGINEERING FOR AN INSPECTION MADE AFTER 1:00 PM MAY
NOT GET PROMPT ATTENTION**

To notify Engineering between 8:30 – 1:30 **(781) 274-8305**
To notify Engineering at other times call
(781) 274-8300 ext 8309 or **8306** for inspections or **8308** for general questions
To contact the DPW (Water/Sewer) please call: **(781) 274-8351**

NOTE:

No Saturday or Sunday work is allowed.

No work is to be started before 7:00 a.m. (Town By-law)

All sewer mains and services will have stone bedding 6-inches deep and to the spring line of the pipe.

All sewer services over 100 feet require a cleanout manhole. Type to be approved by Engineering Department.

Minimum cover over top of pipe is: 6 FT of cover under street pavement
5 FT of cover under driveways & walks
4 FT of cover under lawn areas

All water mains and services per standard details plus sand bedding.

All water unions will be noted on the tie card.

Permits must be issued before construction begins. Work must be done by the permittee.

NO BACKFILLING IS PERMITTED UNTIL PIPE HAS BEEN VISUALLY INSPECTED AND PASSED.

John R. Livsey, P.E.,
Town Engineer
Department of Public Works/Engineering